

Directia de Sanatate Publica
 Caras-Severin
 Laborator diagnostic si investigare in
 Sanatate publica
 Resita, Str..Spitalului, nr.36
 Tel: 0771790490; 0771790496



RAPORT DE INCERCARE APA

Nr....225...

Ziua...01...Luna...04...An...2016.....

Apa analizata – Put captat netratat

Beneficiar : Comuna Sacu

Adresa: Scoala Primara Salbagel Nou

Locatia sursei : Scoala Primara Salbagel Nou

Proba recoltata de...Daminescu Nicolae.....la data 01.04.2016.....ora...8,00.....

Data receptiei...01.04.2016.....ora 10,45.....

Monitorizare audit	Contra cost x	Tematica I.S.S	Monitorizare control
--------------------	---------------	----------------	----------------------

REZULTAT EXAMEN CHIMIC:

Parametrul	unitate de masura	Metoda de analiza	Valoare determinata	Valoare maxima admisa conform Legii 458/2002 Republicata in 2011
Amoniu	mg/l	SR ISO 7150 -1/2001	sd	max 0,5
Nitriti	(mg/l)	SR EN 26777/2002	sd	max 0,5
Nitrati	(mg/l)	SR ISO 7890/3-1998	20,52	max 50
Indice de permanganat	mg,O2/l	SR EN ISO 8467/01	1,13	max 5,0
Turbiditate	grd FTU	SR ISO 7027/2001	-	max.5
Duritate totala	grd germane	SR ISO 6059/2008	-	min 5
Conductivitate	µs/cm	SR EN 27888/97	-	max 2500
Cloruri	mg/l	SR ISO 9297/2001	-	max 250
Fier total	µg/l	SR ISO 6332/1996	-	max 200
pH	Unitati de pH	SR ISO 10523/2012	-	6 -9
Calciu	mg/l	SR ISO 6059/2008	-	x
Magneziu	mg/l	SR ISO 6059/2008	-	x
Clor rezidual liber	mg/l	STAS 6364/1978	-	≥ 0,1 - ≤ 0,5

Observatii : s.d. – sub limita de detectie.

Responsabil incercare:

J. Zagorca
 Chimist

Data emiterii : 06.04.2016

Intocmit.....as.Panduru Pavel.....

Nota: Acest raport a fost eliberat in 2 exemplare

Rezultatul se refera numai la proba analizata

Raportul de incercare nu poate fi reprodus fara aprobarea laboratorului emitent